

The Philadelphia Parking Authority
701 Market Street, Suite 5400
Philadelphia, PA 19106

RFP No. 23-19
Emergency Generator Replacement at Olde City
Addendum Four

To: See Email Distribution List

From: Shannon Stewart
Manager of Contract Administration

Date: February 1, 2024

No Pages: 1

This addendum is issued on February 1, 2024, prior to the proposal due date to add, delete, modify, clarify and/or to respond to questions submitted by prospective offerors regarding the work included in the above referenced solicitation.

QUESTIONS

- 1. Question:** What is the distance between the Generator and the Automatic Transfer Switch (ATS)?
Response: The total distance is 60 feet from the generator and the Automatic Transfer Switch.

END OF ADDENDUM FOUR